



- Fire Hydrant
- ▲ Propane Tank
- Fuel Storage
- Septic Tank
- Oil Storage

NOTE:
 PROVIDE (1) MILLTRONICS TYPE
 MULTIRANGER LEVEL TRANSMITTER
 W/TRANSDUCER (ST25B). 120V IS
 AVAILABLE @ SITE (CONTRACTOR
 VERIFY). PROVIDE 9/8 #14 CU TYPE
 MC, CABLE BACK TO FLOTATION
 AREA ELECTRICAL ROOM (UNDERGROUND
 TO POLE LINE & POLE LINE W/
 MESSENGER WIRE). PROVIDE TERMINAL
 BOXES @ ALL TRANSITIONS OF
 UNDERGROUND TO POLE LINE.

APPROVED
 FOR CONSTRUCTION

ADMMR 0003-17

ADMMR 0003-17

REFERENCES				REVISIONS				REVISIONS				SCALE: 1" = 200'		DATE	
DWG. NO.	TITLE	DWG. NO.	TITLE	NO.	DESCRIPTION	BY	APP'D	DATE	CLIENT	NO.	DESCRIPTION	BY	APP'D	DATE	CLIENT
											DESIGNED BY	PD		OCT 90	
											DRAWN BY	JMR		OCT 90	
											CHECKED BY	M3		NOV 90	
											PROJECT MGR	C.H.		12/19/90	
											CLIENT APPR.	EL		11/90	

M3 Engineering & Technology Corp.
 Tucson, Arizona
 Tel. (602)293-1488 Fax. (602)293-8349

MAGMA GOLD COMPANY
MCCABE PLANT
GENERAL ARRANGEMENT
OVERALL
SITE PLAN

JOB NO. M3 - PN 90151
 DWG. NO. **MC-GA-02**
 REV. NO. 0
 DATE 12/19/90